



Garden State Laboratories, Inc.

Report Date: 10/02/2023

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gsllabs.com
Internet: www.gsllabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Laboratory Manager

For: Full Gospel Christian Academy
531-533 South Orange Ave.

Newark, NJ, 07103

Laboratory Director:

Attention: Robin Bailey

Client Number: FUL07

Sample ID: Full Gospel Christian Academy, 531-533 S. Orange Ave., Newark, NJ/ Field Blank

Lab Sample ID: 230913112-01

Site: Collection Date/Time: 09/12/2023 07:30

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	< 0.0100 mg/l	1.3	0.0100	0.0048	20044	09/28/23 15:37	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	09/22/23 15:46	

Sample ID: Full Gospel Christian Academy, 531-533 S. Orange Ave., Newark, NJ/ Ful07 - 1st Fl. Bathroom

Lab Sample ID: 230913112-02

Site: Collection Date/Time: 09/12/2023 07:30

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.0297 mg/l	1.3	0.0100	0.0048	20044	09/28/23 15:40	
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	09/22/23 15:49	

Sample ID: Full Gospel Christian Academy, 531-533 S. Orange Ave., Newark, NJ/ Ful07 - 1st Fl. Kitchen Sink

Lab Sample ID: 230913112-03

Site: Collection Date/Time: 09/12/2023 07:35

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.0703 mg/l	1.3	0.0100	0.0048	20044	09/28/23 15:43	



Sample ID: Full Gospel Christian Academy, 531-533 S. Orange Ave., Newark, NJ/ Ful07 - 1st Fl. Kitchen Sink

Lab Sample ID: 230913112-03

Site:  Collection Date/Time: 09/12/2023 07:35
 Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00185 mg/l	0.015	0.00100	0.00055	20044	09/22/23 15:52	

Sample ID: Full Gospel Christian Academy, 531-533 S. Orange Ave., Newark, NJ/ Ful07 - 2nd Fl. Class Bathroom

Lab Sample ID: 230913112-04

Site:  Collection Date/Time: 09/12/2023 07:40
 Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Copper, Total Recoverable	EPA 200.7		1	0.0565 mg/l	1.3	0.0100	0.0048	20044	09/28/23 15:47	
Lead, Total Recoverable	EPA 200.9		1	0.00197 mg/l	0.015	0.00100	0.00055	20044	09/22/23 16:03	

DF=Dilution factor, <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit, MDL=Method Detection Limit, SM YR=Standard Methods Publication Year, and NC=Not Certified. The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice. Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

